

TRAINING COURSE: INTRODUCTION TO THE ELJEN GEOTEXTILE SAND FILTER SYSTEM

LESSON 5-1: Maintenance

Minimum Required Maintenance Standards

A maintenance agreement is not a requirement for Eljen permit issuance and the manufacturer should determine the frequency of maintenance activities as specified in the Eljen System owner's manual. Eljen recommends that the maintenance activities and frequency for Geotextile Sand Filter systems be equal to the maintenance activities and frequency specified by the local agency for Elevated Sand mounds.

Homeowner Inspection



Eljen GSF® Listing III.C

The property owner must inspect an on-lot system with an Eljen GSF System every six months. During this inspection, the property owner should verify that there is no ponding of effluent around the absorption area and no down gradient seepage.



Every six months the property owner must inspect the area around the absorption area to ensure that there is no ponding or seepage. No evidence of ponding is shown in this photo of a shallow limiting zone elevated absorption area.



TRAINING COURSE: INTRODUCTION TO THE ELJEN GEOTEXTILE SAND FILTER SYSTEM

LESSON 5-1: Maintenance

Manufacturer Information

The Eljen B43 GSF module is manufactured by the Eljen Corporation based in Connecticut. For additional information, questions, technical assistance, or distributor locations, please contact:

Eljen Corporation

125 McKee St.

East Hartford, CT 06108

Tel: 800-444-1359

Fax: 860-610-0427

Email: info@eljen.com

<http://www.eljen.com>